



**Office of the District Fire Officer,
Banashankari Fire Station,
Karnataka Fire & Emergency Services,
Banashankari 2nd Stage, Bengaluru-560 070.**



No. 32/DFO/BFS/RFSCR-School/2025

Dated: 08-08-2025.

ANNEXURE - 1

Group - B Educational Building

NBC-2016, Part-4, Table 7(11) 3.1.3 Group B Educational Buildings Sub Division B1 & B2.

(These condition are indicative and not exclusive all relevant provisions related to fire and life safety of NBC-2016 are mandatory).

To,
The Authorized Signatory,
M/s. Rajvansh Foundation,
No.86/A, Y.V. Annaiah Road,
Yalachenahalli,
Bengaluru-560 078.

Sir,

Sub : Issue of "**Renewal Fire Safety Compliance Report**" with respect of fire prevention, fire fighting and evacuation measures required at "**M/s. Transcend School, No.86/A, Y.V. Annaiah Road, Yalachenahalli, Bengaluru-560 078.**" - reg.

Ref : 1) CFO Office FSR No.62/CFO/Bng-East/2020, Date:-21-01-2020.
2) This Office FSCR No.50/CFO/Bng-East/2022, Date:-14-11-2022.
3) Your request letter dated: 25-07-2025.
4) FSO Office Inspection Report No:-20 /FSO/BFS/ 2025, Date:- 05-08-2025.

<<<>>>

With reference to the above cited subject, as per Reference (1)& (2), a conditional Fire Safety Recommendation & Fire Safety Compliance Report was issued to the Premises of "**M/s. Transcend School, No.86/A, Y.V. Annaiah Road, Yalachenahalli, Bengaluru-560 078**" with a condition to fulfill the recommendations and compliance the same within three months.

With reference to cited (3) above the management of "**M/s. Transcend School, No.86/A, Y.V. Annaiah Road, Yalachenahalli, Bengaluru-560 078**" had Requested to issue fire safety compliance report from our department.

In this regard as per above reference (4) Fire Station Officer, Banashankari Fire Station was inspected the above addressed premises on 29-07-2025 with respect to Fire prevention and submitted the report.

Under the above Circumstance the Karnataka State Fire & Emergency Services Department Is issuing the "**Renewal Fire Safety Compliance Report**" to "**M/s. Transcend School, No.86/A, Y.V. Annaiah Road, Yalachenahalli, Bengaluru-560 078**" Subject to proper maintenance of fire fighting installations, in the good working condition.



"This Fire Safety compliance Report is issued from the fire prevention and fire fighting point of view Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course."

"In case the fire prevention and fire fighting measures installed in the building as per the recommendation of the department are not maintained in good working condition, if the evacuation measures are not properly followed and if any additional construction work is taken up in the building/premises, This Fire Safety compliance Report deemed to be cancelled and necessary legal action will be initiated against developer/management/ tenant. And also separate NOC has to be obtained from the department for storage of Chemicals, Solvents, Petroleum products(Petrol/Diesel), LPG etc., in the building/premises."

"This Renewal Fire Safety Compliance Report is valid for Only Two years from the date of issue and it is renewable"

Your's Faithfully


DISTRICT FIRE OFFICER
Banashankari Fire Station
Bangalore - 560 070